

PERFORMANCE TESTS IN ACCORDANCE WITH  
AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09




**Report No.:**  
**AI-04370-A1**

**Product Manufacturer:**

LES PORTES ALAIN BOURASSA  
1447 NATIONALE  
TERREBONNE, QUÉBEC  
J6W 6H8  
450-471-8484

**Test Report Summary:**



Product type: Side-Hinged Door  
Product series/model: Single Panel Inswing Wood Door

Primary product designators: **Class CW-PG30 Size tested 1027 x 2155 (40 x 85) - Type SHD**  
**Class CW-PG50 Size tested 1027 x 2155 (40 x 85) - Type LW SHD**

Optional secondary designator: Positive Design pressure (DP) = 2400 Pa (50.0 psf)  
Negative design pressure (DP) = -2400 Pa (-50.0 psf)  
Water penetration resistance test pressure = 220 Pa (4.50 lb/pi<sup>2</sup>)  
Canadian air infiltration / exfiltration level = A3 Level

Test completion date: 2015-03-09  
Report date: 2015-07-16  
Revision date: -  
Number of pages: 7

Note: Reference must be made to Air-Ins Inc. complete report for test specimen description and detailed test results.

Prepared by:

Digitally Signed by:

**Jean Miller, Eng.**

Director, Physical Testing Department  
Air-Ins Inc.

Approved by:

Digitally Signed by:

**Robert Jutras, Eng.**

President  
Air-Ins Inc.



**AIR-INS inc.**

1320, boul. Lionel-Boulet,  
Varenes (Québec) J3X 1P7

☎ (450) 652-0838

☎ (450) 652-7588

✉ info@air-ins.com