

PERFORMANCE TESTS IN ACCORDANCE WITH
AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09



Report No.:
AI-004370-C1

Product Manufacturer:

LES PORTES ALAIN BOURASSA
1447 NATIONALE
TERREBONNE, QUÉBEC
J6W 6H8
450-471-8484

Test Report Summary:

Product type:	Wood Transom	
Product series/model:	Wood Transom (Triple Glazing)	
Primary product designator:	Class CW-PG100: Size tested 2000 x 600 (79 x 24) –Type TR	
Optional secondary designator:	Positive Design pressure (DP) = 4800 Pa (100.0 psf) Negative design pressure (DP) = -4800 Pa (-100.0 psf) Water penetration resistance test pressure = 730 Pa (15.0 psf) Canadian air infiltration / exfiltration level = FIXED	
Test completion date:	2015/08/13	
Report date:	2015/08/19	
Revision date:	-	
Number of pages:	5	
CAN/CSA A440-00 ratings:	FIXED / B7 / C5	

Note: Reference must be made to Air-Ins Inc. complete report for test specimen description and detailed test results.

Prepared by :

Digitally Signed by:

Mikael Tessier, Tech.

Physical Testing Department
Air-Ins Inc.

Approved by :

Digitally Signed by:

Jean Miller, Eng.

Director, Physical Testing Department
Air-Ins Inc.



AIR-INS inc.

1320, boul. Lionel-Boulet,
Varenes (Québec) J3X 1P7

☎ (450) 652-0838

📠 (450) 652-7588

📧 info@air-ins.com